

CENTRAL INSTITUTE FOR TOON RESEARCH,  
REGIONAL STATION, SIRSA-125055 (HARYANA)

Ref. No. F.No. /RS/Stores/

Dated 14.11.2008

M/S Website,  
CICR, Nagpur


Subject : Quotation for On Line UPS 7.5 KVA capacity

Sir,  
Sealed quotation are invited by the Head, CICR, Regional Station, Sirsa for the On Line UPS Standard make 7.5 KVA capacity

**SPECIFICATION : On Line UPS Standard make 7.5 KVA capacity**

1. With 10 Nos. SMF batteries of 12 V /100AH capacity with 120 minute backup with battery rack and interconnecting links.
2. Input voltage single phase 50 Hz & output 230 V  $\pm$  1% ,
3. Rating continuous,
4. Input and output frequency 50Hz.
5. Efficiency better than 90%,
6. Pure sine wave.
7. Rated power fact 0.8,
8. Harmonic distortion(THD) less than 3%
9. Inbuilt isolation transformer facility
10. Charger facility
11. with min.1 year warranty including batteries

1. Quotation along with the make, quality and necessary literature should reach to this office on or before 10-12-2008 along with terms and conditions
2. Maximum period allowed for delivery F.O.R. Regional Station , Sirsa will be 15 days from the date of issuing the purchase order.
3. The Sale Tax or other tax should be mentioned separately. No any forms will be issued.
4. In case supply is not made within the fixed period, the office reserves the right of canceling the order.
5. The payment will be made after completing the delivery /Installation as per specifications and quality given in quotation .
6. Breakage and losses during the transit will have to be borne by the suppliers and charges on such account will be deducted proportionately.
7. The Head, CICR, Regional Station, Sirsa reserves the right to accept or reject the quotation without assigning any reason.
8. On the envelop word QUOTATION for On Line UPS should be written.
9. Material will be accepted only after given satisfactory demonstration.

  
Head,  
CICR, Regional Station, Sirsa.